



# Certificate of Compliance

**Certificate:** 70109400

**Master Contract:** 269249

**Project:** 70109400

**Date Issued:** 2017-01-22

**Issued to:** Schneider Electric Solar Inverters USA, Inc  
250 S VASCO RD, LIVERMORE,  
CA, 94551,  
USA

**Attention:** K. AJITH KUMAR

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:** *Michael Tong*  
Michael Tong

## **PRODUCTS**

CLASS - C531109 - POWER SUPPLIES-Distributed Generation Power Systems Equipment

CLASS - C531189 - POWER SUPPLIES - Distributed Generation-Power Systems Equipment - Certified to U.S. Standards

Utility Interactive Inverter, Model Conext CL-60A, permanently connected.

Note:

For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.

## **APPLICABLE REQUIREMENTS**

CSA C22.2 No. 107.1-01 - General Use Power Supplies

\*UL Std. No. 1741-Second Edition - Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources(January 28, 2010)



**Certificate:** 70109400

**Project:** 70109400

**Master Contract:** 269249

**Date Issued:** 2017-01-22

---

UL 1699B - Outline of Investigation for Photovoltaic (PV) DC Arc-Fault Circuit Protection (Issue Number 2, January 14, 2013)

CSA TIL M-07 - Interim Certification Requirements for Photovoltaic (PV) DC Arc-Fault Protection (Issue Number 1, March 11, 2013)

\*Note: Conformity to UL 1741-Second Edition (January 28, 2010) includes compliance with applicable requirements of IEEE 1547-2003(R2008) and IEEE 1547.1-2005(R2011)